

CONDITIONS OF APPROVAL SUMMARY (PLAT2021-0182)

PLANNING DEPARTMENT: CONDITIONS OF APPROVAL SUMMARY	
PRELIMINARY-FINAL PLAT (Sec. 142-74)	
Not Met	Item Description
x	Sec. 142-74 (a) Site Plan has been approved (for non-residential and multi-family residential projects)
x	Sec. 142-74 (b) (3) Existing Features within 200' of the Subject Property: <ul style="list-style-type: none"> • Property Lines • Streets and Alleys • Easements (including drainage, water, and sewer) • Lot, Block, and Addition Name • Filing Information
x	Sec. 142-74 (b) (6) Title Block with: <ul style="list-style-type: none"> • "Preliminary-Final Plat" • Proposed Addition Name, then Lot(s) and Block(s) <u>OR</u> Number of Lots and Common Areas (Residential Development only) • Acreage • Survey Name and Abstract • City of McKinney, Collin County, Texas • Total Number of Lots and Designation and Amounts of Proposed Uses
x	Sec. 142-74 (b) (6) Name and Address of the Owner and Developer/Engineering/Surveyor (as appropriate)
x	Sec. 142-74 (b) (7) Property within City Limits includes the following notes on each page: <ul style="list-style-type: none"> • "PRELIMINARY-FINAL PLAT: FOR REVIEW PURPOSES ONLY" • "All proposed lots situated in whole or in part within the City's corporate limits comply with the minimum size requirements of the governing zoning district and the requirements of the subdivision ordinance" <u>OR</u> • "All proposed lots situated entirely outside the City's corporate limits and within the City's extraterritorial jurisdiction comply with the requirements of the subdivision ordinance"
x	Sec. 142-74 (b) (7) Two (2) Points tied to State Plane Coordinate System, Texas North Central
x	Sec. 142-74 (b) (7) Approval Certificate with a Signature Block for the Presiding Officer and the Attesting Party

ENGINEERING DEPARTMENT PLAT CHECKLIST

Not Met	Item Description	
<input checked="" type="checkbox"/>	EDM 5.1.G	All proposed water or wastewater facilities that are outside of ROW or existing easements, shall be provided with permanent water or wastewater easement.
<input checked="" type="checkbox"/>	EDM 4.10.B	The following note shall be included on the plat: Minimum maintenance requirements for detention facilities can be found on the Post Construction Stormwater Quality Plan sheet as part of the civil construction plans.

Plat Checklist – FIRE PLAT2021-0194

Met	Not Met	Item Description
<input checked="" type="checkbox"/>	<input type="checkbox"/>	CoM Ord. 142-76.b.4 Proper easements shown at fire hydrant locations
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Fire Ordinance 503.2.1 Platted fire lane and mutual access easement widths shall match approved site plan
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Fire Ordinance 503.2.4 Platted fire lane radii meet minimum requirements for fire lane width and are indicated on the plat.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	CoM Fire Ordinance 503.1.4 Two points of approved fire apparatus access shall be provided for each building, structure and subdivision.