

CONDITIONS OF APPROVAL SUMMARY FOR PLAT2021-0112

PLANNING DEPARTMENT: CONDITIONS OF APPROVAL SUMMARY	
PRELIMINARY-FINAL PLAT (Sec. 142-74)	
Not Met	Item Description
X	<p>Sec. 142-74 (b) (2) Existing Features inside the Subject Property:</p> <ul style="list-style-type: none"> • Streets and Alleys with Width, Name and Filing Information • Easements (including drainage, water, and sewer) with Width, Name and Filing Information • Other Features such as Creeks or Abstract Lines
X	<p>Sec. 142-74 (b) (3) Existing Features within 200' of the Subject Property:</p> <ul style="list-style-type: none"> • Property Lines • Streets and Alleys • Easements (including drainage, water, and sewer) • Lot, Block, and Addition Name • Filing Information
X	<p>Sec. 142-74 (b) (3) Existing Features outside the Subject Property are Ghosted</p>
X	<p>Sec. 142-74 (b) (4) New Features inside the Subject Property showing:</p> <ul style="list-style-type: none"> • Defined Boundary Line of the Subject Property being Subdivided with Accurate Bearings and Distances • Streets and Alleys with Names and Dimensions • Easements with Names and Dimensions • Lots designating Lot Numbers and Blocks and Dimensions • Common Areas (should be defined as "CA-XX" where "XX" is the block and number) • Proposed Street Names • Mutual Access and Fire Lane Easements for Any Lot(s) that do not have Direct Access to a Public Street
X	<p>Sec. 142-74 (b) (6) Name and Address of the Owner and Developer/Engineering/Surveyor (as appropriate)</p>
X	<p>Sec. 142-74 (b) (7) Property within City Limits includes the following notes on each page:</p> <ul style="list-style-type: none"> • "PRELIMINARY-FINAL PLAT: FOR REVIEW PURPOSES ONLY" • "All proposed lots situated in whole or in part within the City's corporate limits comply with the minimum size requirements of the governing zoning district and the requirements of the subdivision ordinance" <u>OR</u> • "All proposed lots situated entirely outside the City's corporate limits and within the City's extraterritorial jurisdiction comply with the requirements of the subdivision ordinance"
X	<p>Sec. 142-74 (b) (7) Approval Certificate with a Signature Block for the Presiding Officer and the Attesting Party</p>
X	<p>Sec. 142-74 (b) (8) Separate Overall Exhibit of the Subdivision on a single page (if a multi-page plat is submitted)</p>

ENGINEERING DEPARTMENT PLAT CHECKLIST

Not Met	Item Description	
<input checked="" type="checkbox"/>	EDM 2.2.A	Functional Classification: Street right-of-way and pavement are provided in accordance with the Master Thoroughfare Plan, Table 2-1, and Figure 2-1.
<input checked="" type="checkbox"/>	EDM 2.6.B	Additional ROW shall be required adjacent to right turn lanes so that there is a minimum of 11 feet of ROW from the back of curb.
<input checked="" type="checkbox"/>	Sec. 142-76.b(3)	The location, width, and description of all easements for right-of-way provided for public services, utilities or fire lanes and any limitations on use of the easements.
<input checked="" type="checkbox"/>	EDM 8.4.D	The plat or separate instrument dedicating the easement shall include a statement of the owner's responsibility for maintenance.
<input checked="" type="checkbox"/>	EDM 5.1.G	Water and wastewater easements shall have a minimum width of 15 feet. Additional easement width shall be provided based on depth and diameter of utilities. The minimum easement width for water and wastewater mains deeper than 10 feet to the bottom of pipe, shall be equal to 2.5 times the depth of the line rounded up to the nearest 5 feet.

Plat Checklist – FIRE PLAT2021-0112

Met	Not Met	Item Description
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Ord. 142-76.b.4 Proper easements shown at fire hydrant locations
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Fire Ordinance 503.2.1 Platted fire lane and mutual access easement widths shall match approved site plan
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Fire Ordinance 503.2.4 Platted fire lane radii meet minimum requirements for fire lane width and are indicated on the plat.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	CoM Fire Ordinance 503.1.4 Two points of approved fire apparatus access shall be provided for each building, structure and subdivision.