

**CONDITIONS OF APPROVAL SUMMARY (PLAT2022-0054)**

<b>PLANNING DEPARTMENT: CONDITIONS OF APPROVAL SUMMARY</b>	
<b>PRELIMINARY-FINAL PLAT (Sec. 142-74)</b>	
<b>Not Met</b>	<b>Item Description</b>
X	<b>Sec. 142-74 (b) (3)</b> Existing Features outside the Subject Property are Ghosted
X	<b>Sec. 142-74 (b) (6)</b> Title Block with: <ul style="list-style-type: none"> <li>• "Preliminary-Final Plat"</li> <li>• Proposed Addition Name, then Lot(s) and Block(s) <u>OR</u> Number of Lots and Common Areas (Residential Development only)</li> <li>• Acreage</li> <li>• Survey Name and Abstract</li> <li>• City of McKinney, Collin County, Texas</li> <li>• Total Number of Lots and Designation and Amounts of Proposed Uses</li> </ul>
X	<b>Sec. 142-74 (b) (7)</b> Approval Certificate with a Signature Block for the Presiding Officer and the Attesting Party

**ENGINEERING DEPARTMENT PLAT CHECKLIST**

<b>Not Met</b>	<b>Item Description</b>	
<input checked="" type="checkbox"/>	EDM 5.1.G	For 2 or more parallel water and wastewater mains in an easement, maintain the centerline of the utility a minimum of 7.5 feet form the edge of the easement