

**CONDITIONS OF APPROVAL SUMMARY (PLAT2022-0099)**

<b>PLANNING DEPARTMENT: CONDITIONS OF APPROVAL SUMMARY</b>	
<b>PRELIMINARY-FINAL PLAT (Sec. 142-74)</b>	
<b>Not Met</b>	<b>Item Description</b>
X	<p><b>Sec. 142-74 (b) (3)</b> Existing Features within 200' of the Subject Property:</p> <ul style="list-style-type: none"> <li>• Property Lines</li> <li>• Streets and Alleys</li> <li>• Easements (including drainage, water, and sewer)</li> <li>• Lot, Block, and Addition Name</li> <li>• Filing Information</li> </ul>
X	<p><b>Sec. 142-74 (b) (4)</b> New Features inside the Subject Property showing:</p> <ul style="list-style-type: none"> <li>• Defined Boundary Line of the Subject Property being Subdivided with Accurate Bearings and Distances</li> <li>• Streets and Alleys with Names and Dimensions</li> <li>• Easements with Names and Dimensions</li> <li>• Lots designating Lot Numbers and Blocks and Dimensions</li> <li>• Common Areas (should be defined as "CA-XX" where "XX" is the block and number)</li> <li>• Proposed Street Names</li> <li>• Mutual Access and Fire Lane Easements for Any Lot(s) that do not have Direct Access to a Public Street</li> </ul>
X	<p><b>Sec. 142-74 (b) (5)</b> Location Map to Show All Major Roads within 1,000' of the Subject Property</p>
X	<p><b>Sec. 142-74 (b) (6)</b> Title Block with:</p> <ul style="list-style-type: none"> <li>• "Preliminary-Final Plat"</li> <li>• Proposed Addition Name, then Lot(s) and Block(s) <u>OR</u> Number of Lots and Common Areas (Residential Development only)</li> <li>• Acreage</li> <li>• Survey Name and Abstract</li> <li>• City of McKinney, Collin County, Texas</li> <li>• Total Number of Lots and Designation and Amounts of Proposed Uses</li> </ul>
X	<p><b>Sec. 142-74 (b) (7)</b> Property within City Limits includes the following notes on each page:</p> <ul style="list-style-type: none"> <li>• "PRELIMINARY-FINAL PLAT: FOR REVIEW PURPOSES ONLY"</li> <li>• "All proposed lots situated in whole or in part within the City's corporate limits comply with the minimum size requirements of the governing zoning district and the requirements of the subdivision ordinance" <u>OR</u></li> <li>• "All proposed lots situated entirely outside the City's corporate limits and within the City's extraterritorial jurisdiction comply with the requirements of the subdivision ordinance"</li> </ul>
X	<p><b>Sec. 142-74 (b) (7)</b> Approval Certificate with a Signature Block for the Presiding Officer and the Attesting Party</p>

**PLAT2022-0099 Checklist - FIRE**

Met	Not Met	Item Description
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>CoM Ord. 142-76.b.4</b> Proper easements shown at fire hydrant locations
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>CoM Fire Ordinance 503.1.4</b> Two points of approved fire apparatus access shall be provided for each building, structure and subdivision.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>2018 IFC C102.1</b> Hydrants shall be spaced along the streets at 500 ft intervals so that all homes are within 250 ft of a hydrant, 200 ft for homes on a dead-end. Not within bulbs of a cul-de-sac.
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>CoM Fire Ordinance 503.1.5</b> Maximum cul-de-sac length shall not exceed 600 ft.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>CoM Fire Ordinance 503.2.2</b> Roadway widths and radii are adequate for fire apparatus access with appropriate radii. Dead-end fire access roads are provided with approved turnaround.

**ENGINEERING DEPARTMENT PLAT CHECKLIST**

<b>Not Met</b>	<b>Item Description</b>	
<input checked="" type="checkbox"/>	EDM 2.3.D	Corner Clips: Corner clip ROW dedications are provided at all street intersections per this section; 25x25 for unsignalized arterial intersections
<input checked="" type="checkbox"/>	Sec. 142-76.b(3)	The location, width, and description of all easements for right-of-way provided for public services, utilities or fire lanes and any limitations on use of the easements.
<input checked="" type="checkbox"/>	EDM 8.4.D	The plat or separate instrument dedicating the easement shall include a statement of the owner's responsibility for maintenance.
<input checked="" type="checkbox"/>	EDM 5.1.G	Water and wastewater easements shall have a minimum width of 15 feet. Additional easement width shall be provided based on depth and diameter of utilities. The minimum easement width for water and wastewater mains deeper than 10 feet to the bottom of pipe, shall be equal to 2.5 times the depth of the line rounded up to the nearest 5 feet.
<input checked="" type="checkbox"/>	EDM 2.2.C	To promote reduced speeds in residential neighborhoods, C2U roadways with residential frontage and all R2U roadways shall not exceed 600 feet in tangent length between curves, bends, and terminus points measured along the centerline of the roadway.
<input checked="" type="checkbox"/>	EDM 5.1.G	In residential developments, water and wastewater mains shall not cross residential lots. Water and wastewater easements shall be located completely on one side of a fence or property line.