

FIRE DEPARTMENT – CONDITIONS OF APPROVAL SUMMARY

PLAT2019-0170

| Not Met | Item Description |
|---------|---|
| X | IFC Appendix B and C Additional hydrant is needed for the homes in the cul-de-sac of the street labeled Cotton Creek Pass |
| X | Fire Variance Approval A portion of Alley K shall be dedicated and striped as a fire lane per the variance request approval. |