

**CONDITIONS OF APPROVAL SUMMARY (PLAT2021-0029)**

<b>PLANNING DEPARTMENT: CONDITIONS OF APPROVAL SUMMARY</b>	
<b>PRELIMINARY-FINAL PLAT (Sec. 142-74)</b>	
<b>Not Met</b>	<b>Item Description</b>
X	<p><b>Sec. 142-74 (b) (3)</b> Existing Features within 200' of the Subject Property:</p> <ul style="list-style-type: none"> <li>• Property Lines</li> <li>• Streets and Alleys</li> <li>• Easements (including drainage, water, and sewer)</li> <li>• Lot, Block, and Addition Name</li> <li>• Filing Information</li> </ul>
X	<p><b>Sec. 142-74 (b) (4)</b> New Features inside the Subject Property showing:</p> <ul style="list-style-type: none"> <li>• Defined Boundary Line of the Subject Property being Subdivided with Accurate Bearings and Distances</li> <li>• Streets and Alleys with Names and Dimensions</li> <li>• Easements with Names and Dimensions</li> <li>• Lots designating Lot Numbers and Blocks and Dimensions</li> <li>• Common Areas (should be defined as "CA-XX" where "XX" is the block and number)</li> <li>• Proposed Street Names</li> <li>• Mutual Access and Fire Lane Easements for Any Lot(s) that do not have Direct Access to a Public Street</li> </ul>
X	<p><b>Sec. 142-74 (b) (7)</b> Two (2) Points tied to State Plane Coordinate System, Texas North Central</p>
X	<p><b>Sec. 142-74 (b) (7)</b> Approval Certificate with a Signature Block for the Presiding Officer and the Attesting Party</p>

**ENGINEERING DEPARTMENT PLAT CHECKLIST**

<b>Not Met</b>	<b>Item Description</b>	
<input checked="" type="checkbox"/>	Sec. 142-74.b	Identify the widths of any and all proposed streets, alleys and easements.

**PLAT2021-0019 Checklist - FIRE**

Met	Not Met	Item Description
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>CoM Ord. 142-76.b.4</b> Proper easements shown at fire hydrant locations
<input type="checkbox"/>	<input checked="" type="checkbox"/>	<b>2018 IFC C102.1</b> Hydrants shall be spaced along the streets at 500 ft intervals so that all homes are within 250 ft of a hydrant, 200 ft for homes on a dead-end
<input type="checkbox"/>	<input type="checkbox"/>	<b>CoM Fire Ordinance 503.2.4</b> Platted fire lane radii meet minimum requirements for fire lane width and are shown on a curve table
<input checked="" type="checkbox"/>	<input type="checkbox"/>	<b>CoM Fire Ordinance 503.1.4</b> Two points of approved fire apparatus access shall be provided for each building, structure and subdivision.
<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/>	<input type="checkbox"/>	