

CONDITIONS OF APPROVAL SUMMARY (PLAT2020-0084)

PLANNING DEPARTMENT: CONDITIONS OF APPROVAL SUMMARY	
PRELIMINARY-FINAL PLAT (Sec. 142-74)	
Not Met	Item Description
X	Sec. 142-74 (b) (2) Existing Features inside the Subject Property: <ul style="list-style-type: none"> • Streets and Alleys with Width, Name and Filing Information • Easements (including drainage, water, and sewer) with Width, Name and Filing Information • Other Features such as Creeks or Abstract Lines
X	Sec. 142-74 (b) (3) Existing Features within 200' of the Subject Property: <ul style="list-style-type: none"> • Property Lines • Streets and Alleys • Easements (including drainage, water, and sewer) • Lot, Block, and Addition Name • Filing Information
X	Sec. 142-74 (b) (3) Existing Features outside the Subject Property are Ghosted
X	Sec. 142-74 (b) (4) New Features inside the Subject Property showing: <ul style="list-style-type: none"> • Defined Boundary Line of the Subject Property being Subdivided with Accurate Bearings and Distances • Streets and Alleys with Names and Dimensions • Easements with Names and Dimensions • Lots designating Lot Numbers and Blocks and Dimensions • Mutual Access and Fire Lane Easements for Any Lot(s) that do not have Direct Access to a Public Street
X	Sec. 142-74 (b) (6) Name and Address of the Owner and Developer/Engineering/Surveyor (as appropriate)
X	Sec. 142-74 (b) (7) Approval Certificate with a Signature Block for the Presiding Officer and the Attesting Party

Plat Checklist – FIRE PLAT2020-0084

Met	Not Met	Item Description
<input checked="" type="checkbox"/>	<input type="checkbox"/>	CoM Ord. 142-76.b.4 Proper easements shown at fire hydrant locations
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Fire Ordinance 503.2.1 Platted fire lane and mutual access easement widths shall match approved site plan
<input type="checkbox"/>	<input checked="" type="checkbox"/>	CoM Fire Ordinance 503.2.4 Platted fire lane radii meet minimum requirements for fire lane width and are shown on a curve table
<input checked="" type="checkbox"/>	<input type="checkbox"/>	CoM Fire Ordinance 503.1.4 Two points of approved fire apparatus access shall be provided for each building, structure and subdivision.
<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/>	<input type="checkbox"/>	
<input type="checkbox"/>	<input type="checkbox"/>	